



**Public Record – Summary Information**  
**On Motor Fuel Underground Storage Tanks (USTs)**  
 Public Record Posted Date: 1-10-24

**General Information**

Total Number of Active Federal UST Facilities: 472  
 Total Number of Active Federal USTs: 1,089  
 Total Number of Active and Inactive Federal Leaking UST (LUST) Cases: 1519  
 Total Number of Active Federal LUST Cases: 131

**Summary Information for On-Site Inspections**

Inspection Period Dates: October 1, 2022 - September 30, 2023

Number of UST Facilities Inspected: 150  
 Technical Compliance Rate 31%

**Note:** Tank, facility, and on-site inspection information is based on inspections of UST motor fuel facilities only; heating oil USTs are not included. On-site inspections measure compliance with [State of Rhode Island](#) and [U.S. EPA](#) regulations governing the prevention and detection of petroleum releases or discharges from underground storage tanks.

**Summary Information for Releases**

Number of Confirmed UST Releases: **10**

Release Reporting Period Dates: October 1, 2022, through September 30, 2023

Source			Cause											
			Spill/Overfill		Phy/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	4	40%					1	25%					3	75%
Piping		%												
Dispenser	1	10%	1	100%										
STP		%												
Delivery Problem		%												
Unknown	3	30%											3	100 %
Other (sump)	2	20%	2	100%										
Totals	10	100%	3	30%		%	1	10%					6	60%

# = number  
 % = percent of releases by source *or* percent of causes by source

**Note:** Source and cause data were compiled from data collected during the investigation of UST system releases such as new Federal LUST Cases.

For site specific information, please contact:  
 Jessica Carney-Almeida (Phone 401-537-4312); [jessica.carney@dem.ri.gov](mailto:jessica.carney@dem.ri.gov)