



Public Record – Summary Information
On Motor Fuel Underground Storage Tanks (USTs)
 Public Record Posted Date: 1/9/2025

General Information

Total Number of Active Federal UST Facilities: 464
 Total Number of Active Federal USTs: 1081
 Total Number of Active and Inactive Federal Leaking UST (LUST) Cases: 1,527
 Total Number of Active Federal LUST Cases: 128

Summary Information for On-Site Inspections

Inspection Period Dates: October 1, 2023 - September 30, 2024

Number of UST Facilities Inspected: 216
 Technical Compliance Rate 33%

Note: Tank, facility, and on-site inspection information is based on inspections of UST motor fuel facilities only; heating oil USTs are not included. On-site inspections measure compliance with [State of Rhode Island](#) and [U.S. EPA](#) regulations governing the prevention and detection of petroleum releases or discharges from underground storage tanks.

Summary Information for Releases

Number of Confirmed UST Releases: **10**

Release Reporting Period Dates: October 1, 2023, through September 30, 2024

Source			Cause											
			Spill/Overfill		Phy/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	2	20%			1	10%	1	10%						0%
Piping		%												0%
Dispenser	2	20%											2	20%
STP	4	40%								1	10%		3	30%
Delivery Problem		%												0%
Unknown	2	20%											2	20%
Other (sump)		%												
Totals	10	100%	0		1	10%	1	10%			1	10%	7	70%
# = number														
% = percent of releases by source <i>or</i> percent of causes by source														

Note: Source and cause data were compiled from data collected during the investigation of UST system releases such as new Federal LUST Cases.

For site specific information, please contact:
 Jessica Carney-Almeida (Phone 401-537-4312); jessica.carney@dem.ri.gov