



Public Record – Summary Information
On Motor Fuel Underground Storage Tanks (USTs)
 Public Record Posted Date: 12-1-22

General Information

Total Number of Active Federal UST Facilities: 476
 Total Number of Active Federal USTs: 1,097
 Total Number of Active and Inactive Federal Leaking UST (LUST) Cases: 1513
 Total Number of Active Federal LUST Cases: 141

Summary Information for On-Site Inspections

Inspection Period Dates: October 13, 2020 - September 30, 2021

Number of UST Facilities Inspected: 125
 Technical Compliance Rate 43%

Note: Tank, facility, and on-site inspection information is based on inspections of UST motor fuel facilities only; heating oil USTs are not included. On-site inspections measure compliance with [State of Rhode Island](#) and [U.S. EPA](#) regulations governing the prevention and detection of petroleum releases or discharges from underground storage tanks.

7

Summary Information for Releases

Number of Confirmed UST Releases: **16**

Release Reporting Period Dates: October 1, 2021, through September 30, 2022

Source			Cause											
			Spill/Overfill		Phy/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	3	19%					3	100%						
Piping		%												
Dispenser	4	25%	2	50%									2	50%
STP		%												
Delivery Problem		%												
Unknown	7	43%	3	43%									4	57%
Other	2	13%	2	100%										
Totals	16	100%	7	44%			3	19%					6	37%

= number
 % = percent of releases by source *or* percent of causes by source

Note: Source and cause data were compiled from data collected during the investigation of UST system releases such as new Federal LUST Cases.

For site specific information, please contact:
 Kevin Gillen (Phone 401-222-4700 ext. 277-7116; Kevin.Gillen@dem.ri.gov)