



Public Record – Summary Information On Motor Fuel Underground Storage Tanks (USTs)

Public Record Posted Date: 10/21/2021

General Information

Total Number of Active Federal UST Facilities:	479
Total Number of Active Federal USTs:	1,086
Total Number of Active and Inactive Federal Leaking UST (LUST) Cases:	1499
Total Number of Active Federal LUST Cases:	145

Summary Information for On-Site Inspections

Inspection Period Dates: October 1, 2020 - September 30, 2021

Number of UST Facilities Inspected: 231

Release Prevention Compliant:	67%
Release Detection Compliant:	58%
Percent Compliance (Combined Measure):	46%

Note: Tank, facility, and on-site inspection information is based on inspections of UST motor fuel facilities only; heating oil USTs are not included. On-site inspections measure compliance with [State of Rhode Island](#) and [U.S. EPA](#) regulations governing the prevention and detection of petroleum releases or discharges from underground storage tanks.

Summary Information for Releases

Number of Confirmed UST Releases: **11**

Release Reporting Period Dates: October 1, 2020 through September 30, 2021

Source			Cause											
			Spill/ Overfill		Phy/Mech Damage		Corrosion		Install Problem		Other**		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	5	45%			1	20%	3	60%					1	20%
Piping	1	9%											1	100%
Dispenser		0%												
STP		0%												
Delivery Problem		0%											0	
Unknown	5	45%											5	100%
Other*		0%												
Totals	11	100%			1	9%	3	27%					7	64%

= number
% = percent of releases by source *or* percent of causes by source

Note: Source and cause data were compiled from data collected during the investigation of UST system releases such as new Federal LUST Cases.

For site specific information, please contact:
Lillian Zemba (Phone 401-222-4700 ext. 2774317; lillian.zemba@dem.ri.gov.)