

Office of Surface Water Protection
Operations & Maintenance Section

Regulatory Expectations For Wastewater Collection and Treatment Operations and Maintenance

Version: October 14, 2020



Revision: October 14, 2020

Contents

1. Sanitary Sewer Overflow/RIPDES Max Daily Noncompliance/Facility Upset Reporting2
2. RIPDES Weekly and Monthly Non-Compliance notification
3. Suggested notifications
4. Bacteria testing during SSOs, times of possible disinfection issues, and availability of 24-hour
bacteriological sampling3
5. Bacteriological sampling: Accuracy and dilutions
6. Split samples to check quality assurance4
7. MOR/bioassay reporting5
8. Reporting loads5
9. NetDMR: resubmitting data5
10. NetDMR: naming conventions5
11. NetDMR: submitting attachments as PDF files6
12. WWTF and Collection System Improvements6
13. Primary and Backup Sludge Disposal Plans6
14. Air Resources requirements
15. Standard Work/Script for off-hour call in8

THIS DOCUMENT IS MEANT AS A HELPFUL SUMMARY AND EXPLANATION OF IMPORTANT REGULATORY EXPECTATIONS FOR THE OPERATIONS AND MAINTENANCE OF WASTEWATER COLLECTION AND TREATMENT INFRASTRUCTURE. THIS SUMMARY IS BASED ON FREQUENTLY ASKED QUESTIONS AND COMMON ERRORS OBSERVED BY DEM'S OPERATIONS & MAINTENANCE SECTION. IT IS NOT MEANT AS A COMPREHENSIVE LIST NOR DOES IT REPLACE A THOROUGH READING OF THE REGULATIONS AND PERMIT LANGUAGE.

WHEN REVIEWING THIS DOCUMENT, PLEASE CONTACT A MEMBER OF THE OPERATIONS & MAINTENANCE SECTION WITH ANY QUESTIONS.



Revision: October 14, 2020

1. Sanitary Sewer Overflow/RIPDES Max Daily Noncompliance/Facility Upset Reporting

Immediate notification to DEM: Please be reminded that the Regulations for the Rhode Island Pollution Discharge Elimination System (250-RICR-150-10-1-14.R) require the immediate reporting to DEM of any noncompliance which may endanger health or the environment. In addition, unless waived by DEM, a written report must also be provided, physically or electronically, within five days, to the Operations & Maintenance Section. Finally, the noncompliance must be reported as part of monthly DMR submissions.

For the purposes of this requirement, noncompliance is defined as events denoted in the above-referenced Rule 14.R. These include:

- Any bypass (whether in the collection system or the treatment works) that results in the
 exceedance of any effluent limitation in the facility's RIPDES permit. Unless sampling data
 proves otherwise, the DEM will assume that the following bypasses will exceed effluent
 limitations:
 - o All overflows into state waters within the collection system
 - o All plant bypasses of final disinfection
- Any plant upset that has the potential to result in an exceedance of any maximum daily effluent limitation in the facility's RIPDES permit. Such upsets may include but are not limited to a final disinfection failure, evidence of the presence of incoming inhibitory substances, or solids washout.
- Exceedances noted above that must be reported immediately are only those violations of a maximum daily discharge limitation for pollutants listed in the facility permit.

The immediacy of reporting is critical to the health and welfare of the State of Rhode Island. After you verbally notify DEM of an event, our office notifies our colleagues in DEM's Shellfishing section, the US EPA, the Rhode Island Department of Health, DEM management, and DEM public information staff so that appropriate statewide actions can be taken to protect public health and the environment. As such, please provide as much information as possible in the initial verbal report, with the understanding that additional information will also be provided as it becomes available. As such, please be reminded that failure to report non-compliance in accordance with state law and regulations may in itself be considered an enforceable event, which may include the forwarding of the matter to the Board of Certification of Operators of Wastewater Treatment Facilities for their review of any operator misconduct.

Because leaving emergency reports on voicemail is prohibited, DEM's administrative staff have been trained to take your verbal reports if you cannot connect with a member of the O&M section. When speaking with a member of DEM's administrative staff, you need not provide detailed information. Their role is simply to notify someone from the O&M section of the reported event, as well as basic information of the nature of the event and contact information. This applies to your calls to DEM's enforcement section, too, who have been trained to respond to your calls following the Standard Work "Script" on the final page of this document. As you may recall, this script provides guidance for both the caller and the DEM dispatchers on the content and order of that conversation.

Special COVID/teleworking addendum: Until further notice, the following Google-based phone numbers are available for contact with O&M staff during normal business hours:

• Matt Puglia: (401) 484-7412

Anthony Sylvia: (401) 526-3838

• Bill Patenaude: (401) 484-8216



Revision: October 14, 2020

If you're speaking with a member of the dispatch unit after hours or an administrative staff member during business hours, it's suggested that you ask for their name. That will not only be helpful for your records but can assist DEM in the event of any concerns you have about ease of reporting.

The written report, to be submitted within 5 days: If you are required to submit a written report as a result of a collection system overflows and plant upset, please use DEM's Office of Water Resources Sanitary Sewer Overflow and Bypass Questionnaire. A copy is enclosed and is on our DEM wastewater facility website (http://www.dem.ri.gov/programs/benviron/water/permits/wtf/pdfs/overflow.pdf) under the link "Reporting Sewage Overflows." Remember that the written report is required to be submitted to the DEM within five business days of the event's conclusion (in accordance with Part II(l) of your RIPDES permit).

2. RIPDES Weekly and Monthly Non-Compliance notification

24-hour reporting to DEM: DEM has regularly reminded superintendents of the requirement to report *all known weekly and monthly permit violations* to this office within 24 hours of becoming aware of a violation. Such notification is required under Part II(l) of your RIPDES permit and previously noted Rule 14.R of the Regulations for the Rhode Island Pollution Discharge Elimination System.

As with Item 1, requirements for notification exist so that this agency, in conjunction with the Department of Health, can take necessary and timely steps to protect public health and the environment.

3. Suggested notifications

It is also encouraged, but not required, that facilities update DEM should there be a planned or unplanned reduction of process equipment availability, even if such reductions do not result in permit non-compliance. In general, it's always helpful to keep your DEM's Operations and Maintenance Section aware of significant changes in plant or collection system status even if no process issues are expected.

4. Bacteria testing during SSOs, times of possible disinfection issues, and availability of 24-hour bacteriological sampling

While DEM must take all necessary, timely, and prudent steps to protect public health and the environment in the event of a discharge of raw or partially treated sewage, it also wishes to avoid unnecessary advisories or shellfish closures that will impact the use of public waters—especially the shellfishing industry and its consumers—as well as the reputation of your facility and staff. Without adequate data about impacts to state waters as a result of an SSO or a failure at your wastewater treatment facility, DEM must assume a "worst case scenario" and take action based on that assumption to protect public health.

To prevent unnecessary shellfish closures or other advisories, the DEM has in the past required increased levels of monitoring for fecal coliform and (if required by your permit) enterococci during a failure at your plant or as a result of an SSO that discharges to state waters.



Revision: October 14, 2020

Authority for this requirement comes under Part 4.10 D and E of the Rules and Regulations for the Operations and Maintenance of Wastewater Treatment Facilities (250-RICR-150-10-4).

Therefore, please be advised that in the event of evidence of inadequate disinfection at your facility or in the event of an SSO that is likely to impact state waters, bacteriological samples must be taken for those parameters required by your RIPDES permit. DEM will provide specific guidance for sampling and reporting on a case-by-case basis. However, should you be unable to speak with a DEM official for such guidance, the default protocol is to sample and test for fecal coliform and (if required by your permit) enterococci at the following times:

- (i) at the initial determination that there is evidence of inadequate disinfection,
- (ii) approximately one hour after the attempted correction of the cause of inadequate disinfection,
- (iii) and at least daily should the cause of inadequate disinfection remain unresolved,

No sampling should be attempted if there is a reasonable threat to operator safety.

Again, so that DEM can make timely and prudent determinations regarding public health advisories, samples must be tested with a sufficient number of dilutions (see item 5 below) to achieve meaningful results. Moreover, analysts must employ methods such as the A1 modified method which provide a result in 24 hours. All results must be reported to DEM. As such, it is in your facility's best interest to initiate and maintain ongoing communication with the DEM during such events.

Please be reminded that wastewater treatment facilities which use contract laboratories for bacteria sampling must have the option to collect and sample for bacteria during the nighttime and weekends. The DEM notified the wastewater community of this requirement in December 2005. As such all facilities should confirm and review their procedures—whether internal or contractual—for the testing of fecal coliform within the prescribed eight-hour holding time.

Please be notified that failure to determine a fecal count during a condition of actual or suspected disinfection failure (that is, actual or assumed due to alarm conditions, etc.) will require the Department to assume a worst-case scenario of 24 million MPN/100 ml for a bacteria count.

5. Bacteriological sampling: Accuracy and dilutions

The EPA-approved "MPN" method for bacteriological analysis allows, as a minimum, 5 tubes and 3 dilutions for the testing and calculation of the fecal coliform, which yields a maximum result of 1,600 MPN/100ml. The Department urges facilities to expand the number of dilutions as needed so that a more accurate fecal count can be attained. Should the number of dilutions only result in the determination of ">1,600 MPN/100ml," DEM will assume a worst-case of 24 million MPN/100 ml.

6. Split samples to check quality assurance

DEM suggests that facilities perform split samples with other laboratories in the event of three consecutive sampling results (such as for fecal coliform or enterococci) that indicate unexpectedly high values, especially if other pollutants are not elevated. Split sampling with another laboratory may assist you in determining the possibility of quality assurance issues with your current laboratory.



Revision: October 14, 2020

7. MOR/bioassay reporting

Permittees are required to submit monthly monitoring data to DEM in discharge monitoring reports (DMRs) electronically using NetDMR. Said reports must be submitted no later than the 15th day of the month following the month for which the data is being submitted. Hard copies of DMRs should not be submitted to DEM. The permittee must also submit copies of documents that are directly related to the DMR electronically in NetDMR. These include the following: DMR Cover Letters, Below Detection Limit summary tables, Wet Weather Event Summary Reports, and Monthly Operating Reports. All other reports/notifications shall be submitted to the DEM as a hard copy with a cover letter describing the submission, unless specified otherwise in your permit/by DEM. These reports shall be signed and dated originals and include the following: Written notifications required under Part II of your permit; Notice of unauthorized discharges including SSO reporting; Priority Pollutant Scan results; Infiltration/Inflow Reports; Pretreatment Reports, etc.

8. Reporting loads

When calculating the pollutant load, use the following formula:

Load (lbs/day) = Concentration (mg/l) x Flow (MGD) x 8.34 (a conversion factor)

Use each sample concentration and multiply it by the flow on the day that the sample was taken and by the conversion factor. The monthly average is calculated using each individual day's loading. For the sole purpose of calculating pollutant loads in lb/day, if the concentration value is less than the detection limit, use the detection limit in mg/l in the loading calculation shown above, not zero.

9. NetDMR: resubmitting data

If you must resubmit data using NetDMR, please include a brief cover letter (one or two sentences will do) to explain what data you are updating. As NetDMR completely rewrites such data, DEM and EPA are otherwise unable to easily determine the nature of your changes.

10. NetDMR: naming conventions

In order to standardize the way reports are named when submitted as an attachment using NetDMR, each report should use the following convention consisting of the RIPDES permit ##, the Report Type Name (see below), and the year and month the report covers:

RIPDESPermit#_ReportTypeName_YYYY_MM

Report Name	Report Attachment Naming
CSO Report	PERMITID_CSO_YYYY_MM
DMR Cover Letter	PERMITID_DMRCov_YYYY_MM
Monthly Operating Reports	PERMITID_MOR_YYYY_MM

For example, if the Woonsocket WWTF was submitting its monthly operating report for July of 2021 as an attachment, the report name would be: RI0100111_MOR_2021_July



Revision: October 14, 2020

11. NetDMR: submitting attachments as PDF files

DEM prefers that attachments be submitted in PDF format. If possible, you should submit PDFs that are software-generated rather than paper scans (with the exception of signed cover letters). Some facilities scan their MORs because the superintendent signs or initials each page of the MOR. DEM does not require such signing or initialing of MORs if submitting electronically.

12. WWTF and Collection System Improvements

Any improvements to equipment at a WWTF require a design review and Order of Approval from DEM's Wastewater Planning & Design program prior to construction. Projects that involve the replacement of existing equipment with the same or in-kind equipment are not subject to DEM approval, provided the new equipment does not change or affect any treatment process and/or change hydraulic loadings to any treatment process. If there are questions regarding whether approval is required, contact a member of the Operations and Maintenance Section or the Wastewater Planning & Design program for a determination. Please also be aware that any proposed collection system sewer extensions with an average daily design flow of greater than 30,000 gpd requires an Order of Approval from DEM. This includes municipal and private sewers and pump stations.

13. Primary and Backup Sludge Disposal Plans

Please be reminded that wastewater managers should regularly review their facility's primary sludge disposal plans for accuracy and, if necessary, submit updated plans to DEM for review and approval.

As part for this review, wastewater managers are expected to confirm that the information within the most recently approved Application for Order of Approval remains up-to-date and accurate. Examples of such a confirmation include sludge transporter information and the transporter's ability to perform, as well as the viability of the facility's backup disposal plans and procedures, as discussed below.

Please note, every facility is required to have a backup/contingency disposal option to complement its primary disposal method(s).

Such backup plans are especially important considering current stresses on regional and local sludge disposal options. As such, facility managers are expected to review their backup options and update them, as necessary. Note that using the RI Resource Recovery Corporation landfill as backup alone may no longer be a consistently available option and plants should consider additional options.

Facility management must ensure that sludge transporters listed in the Application for OA are up to date. Should a change in transporters be needed, facility managers must submit an updated Applications for an Order of Approval.

Last, DEM strongly encourages every WWTF manager to maintain an ongoing review and analysis of—as well as respond to changes in—local and regional sludge transportation, capacity, and disposal options.



Revision: October 14, 2020

14. Air Resources requirements

The following two reminders are requirements of DEM Office of Air Resources, per 250-RICR-120-05-17 ("Odors"):

- Odors detected outside of your property line that result from the operations of wastewater collection
 or treatment systems are a violation per Rule 9 of DEM's Operations and Maintenance Regulations
 (250-RICR-150-10-4) and Rule 17 of DEM's Air Pollution Control Regulation (250-RICR-120-05-17).
 (This Rule is repeated in Part 4.9 of the Rules and Regulations for the Operations and Maintenance of
 Wastewater Treatment Facilities.)
- Any emergency generator where the engine is 50 HP or larger (heat input capacity of 350,000 BTUs or more per hour) and started up on or after November 15, 2007 requires a permit from the DEM's Office of Air Resources prior to installation. Please note that most new emergency generator installations might be eligible for a General Permit, which involves an administratively simpler permitting process than the minor source permitting process in DEM's Air Pollution Control Regulation No. 9. For more information about the permitting requirements for emergency generators contact DEM's Office of Air Resources at 222-2808.

	7.3	Process Name:		Standard Work Instruction Sheet				
Seq. No	WWTF Call To DEM Law Enforcement FOR USE DURING NON- BUSINESS HOURS		SWIS# DEM-DLE-00			REV # 3	0	
	ELEMENTS OF OPERATION		JOB LAYOUT (details)					
1	WWTF : CALL DEM	1 DISPATCH 401-222-3070						
2	"This is a Wastew Facility/Community the contact numb called if additional in	patcher answers, inform dispatcher vater Event Call from (Name of and name is (state your full name) and per is (provide a phone number that can be and name) is needed). The event is a call category titles in boxes 4, 5, or 6.)"	If call is sewage related but not one of the SEW categories:		Wasi	1 tewater Event Call		
3	appropriate call-r information, in wl "Unknown." OTHI	the numbered questions in the eason box. Note: Caller may not have all nich case record the information as ER SEWERAGE CALLS USE SEPTIC DW & VIO (Code: ISDS)	Ove	eptic ystem erflow & Vio ISDS)		2	Based on caller event	
4	failure?" 2. "What is the known?" 3. "Are you rep what are the 4. "What is the	ons: enature of the process or equipment approximate start time and end time, if orting known permit violations, if so, y?" approximate flow volume of any ntreated discharge?"	3 type, proceed to either 4, 5, 6, or 7 OR OR OR FRANCE OR OR SEW-V SEW-O					
5	Dispatcher questi 1. "What is the 2. "What is the known?" 3. "What water 4. "What is the known?"	location of the event?" approximate start time and end time, if bodies, if any, are impacted?" estimated volume or flow rate, if						
6	FOR A SEW. PLAN Dispatcher questi 1. "What is the 2. "What is the 3. "Is this violat	IT PERMIT VIO: ions: parameter violated?" approximate numerical value and unit?" ion the result of a plant failure? e briefly explain."				9		
7	Dispatcher questi 1. "Nature of v 2. "What water	TEGORY, USE: SEW. DISCHARGE OTHER: ions: iolation or issue." bodies, if any, are impacted?" estimated volume or flow rate?"	e." are impacted?"					
8	WWTF : Ask for th	e name of the dispatcher.	Example of Plant Location (#					
9	DLE/WWTF: End	call.	1-1-				Collection Location (#5)	
RE	REQUIRED SKILLS Effective Date:		TBD Patenguide		le le	Revisions Highlighted in Yellow		
	-	Supervisor Approval:	Steve Criscione Lou Maccarone			Page 1 of 1		
	I	PP	8		-			
6 7 8 9	known?" 3. "What water 4. "What is the known?" (End questions: G FOR A SEW. PLAN Dispatcher questi 1. "What is the 2. "What is the 3. "Is this violat 4. "If yes, pleas (End questions: G IF UNSURE OF CA Dispatcher questi 1. "Nature of v 2. "What water 3. "What is the WWTF: Ask for th DLE/WWTF: End of	bodies, if any, are impacted?" estimated volume or flow rate, if to to Box 8) IT PERMIT VIO: fons: parameter violated?" approximate numerical value and unit?" ion the result of a plant failure? e briefly explain." to to Box 8) TEGORY, USE: SEW. DISCHARGE OTHER: fons: iolation or issue." bodies, if any, are impacted?" estimated volume or flow rate?" e name of the dispatcher. call. Effective Date: Author:	Bill F Steve Lou N	TBD Patenaud Criscion	le ne	9 Example of Revisions H	lighlighted in Yellow	